[1] Information sheet (Lot.21)

 $_{[2]}$ This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) 2016/2281.

Model information

Outdoor unit / Indoor unit	AOYG54LATT / ARYG54LHTA
Outdoor side heat exchanger of air conditioner	Air
Indoor side heat exchanger of air conditioner	Air
Compressor type / driver of compressor	Vapour compression / Electric motor

			Coo	ling			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated cooling capacity	P _{rated,c}	14.0	kW	Seasonal space cooling energy efficiency	$\eta_{s,c}$	181.0	%
Declared cooling capacity for part load at given outdoor temperatures Tj and indoor 27°/19 °C (dry/wet bulb)			Declared energy efficiency ratio for part load at given outdoor temperatures Tj				
T _j = + 35 °C	Pdc	14.00	kW	Tj = + 35 °C	EER _d	3.01	_
T _j = + 30 °C	Pdc	10.32	kW	Tj = + 30 °C	EER _d	3.94	_
T _j = + 25 °C	Pdc	6.63	kW	Tj = + 25 °C	EER _d	5.61	_
T _j = + 20 °C	Pdc	5.87	kW	Tj = + 20 °C	EER _d	5.98	_
Degradation co-efficient for air conditioners	C _{dc}	0.25	_	_	_	_	-
	Po	wer consum	otion in mod	es other than 'active mode'			
Off mode	P _{OFF}	0.018	kW	Crankcase heater mode	P _{CK}	0.000	kW
Thermostat-off mode	P _{TO}	0.103	kW	Standby mode	P _{SB}	0.018	kW

			Hea	iting			
Rated heating capacity	P _{rated,h}	16.0	kW	Seasonal space heating energy efficiency	$\eta_{s,h}$	133.0	%
Declared heating capacity for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance for part load at given outdoor temperatures Tj			
$T_j = -7 ^{\circ}C$	Pdh	9.20	kW	$T_j = -7 ^{\circ}C$	COP _d	2.73	_
T _j = + 2 °C	Pdh	5.60	kW	T _j = + 2 °C	COP _d	3.29	_
T _j = + 7 °C	Pdh	5.26	kW	T _j = + 7 °C	COP _d	3.98	_
T _j = + 12 °C	Pdh	6.53	kW	T _j = + 12 °C	COP _d	4.90	_
T _{biv} = bivalent temperature	Pdh	9.20	kW	T _{biv} = bivalent temperature	COP _d	2.73	_
T _{OL} = operation limit	Pdh	9.55	kW	T _{OL} = operation limit	COP _d	2.14	_
Bivalent temperature	T _{biv}	-7	°C				
Degradation co-efficient heat pumps	C_{dh}	0.25	_	_	_	_	1
Power consumption in modes other than 'active mode'				Supplementary heater			
Off mode	P _{OFF}	0.018	kW	Back-up heating capacity	elbu	1.07	kW
Thermostat-off mode	P _{TO}	0.018	kW	Type of energy input Electri		ricity	
Crankcase heater mode	P _{CK}	0.000	kW	Standby mode	P _{SB}	0.018	kW

Other items								
Capacity control		Variable			GWP of the refrigerant		2088	kg CO _{2 eq} (100 years)
(Indoor unit /	Cooling	L _{WA}	75.0 / 70.0	dB	Air flow rate, outdoor measured	Cooling	6900	m³/h
	Heating	L _{WA}	74.0 / 72.0	dB		Heating	6900	m³/h
Contact details				FUJITSU GENERAL LIMITED 3-3-17,Suenaga, Takatsu-ku, Kawasaki 213-8502, Japan				

V20170928

